



Massachusetts Department of Environmental Protection - Drinking Water Program  
**Per- and Polyfluoroalkyl Substances (PFAS) Report**

**PFAS**

**I. PWS INFORMATION:** Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: **3164000** City/Town: **LYNNFIELD**  
 PWS Name: **LYNNFIELD CENTER WATER DISTRICT** PWS Class: **COM** NTNC  TNC

DEP LOCATION (LOC) ID#	DEP Location Name	Sample Information	Date Collected	Collected By
10275	STA. #4 (GLEN DRIVE WELLS 5G-8G)	<input type="checkbox"/> (M)ultiple <input type="checkbox"/> (R)aw <input type="checkbox"/> (S)ingle <input type="checkbox"/> (F)inished	12/20/2021	N. Couris/B. Deshaies
Routine or Special Sample <input checked="" type="checkbox"/> RS <input type="checkbox"/> SS		Original, Resubmitted or Confirmation Report <input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation		
		If Resubmitted Report, list below: (1) Reason for Resubmission: <input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction (2) Collection Date of Original Sample:		

**SAMPLE NOTES** - (Such as, if a Manifold/Multiple sample, list any sources that were on-line during sample collection).

**II. ANALYTICAL LABORATORY INFORMATION:**

Primary Lab Cert. #: **M-MA1118** Primary Lab Name: **Nashoba Analytical, LLC**  
 Analysis Lab Cert. #: **M-MA072** Analysis Lab Name: **New England Chromachem** Subcontracted? (Y/N) **Y**

If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Lab Sample IDs#
EPA537.1	12/28/2021	12/30/2021	1	Primary Lab: 237417-2 Subcontracted Lab: 112386

CAS #	Regulated PFAS Contaminants	Result ng/L	Result Qualifier	MCL ng/L	MDL ng/L	MRL ng/L
1763-23-1	PERFLUOROOCETANESULFONIC ACID-PFOS	1.79	J		0.578	2.00
335-67-1	PERFLUOROOCETANOIC ACID-PFOA	4.65			0.578	2.00
355-46-4	PERFLUOROHEXANESULFONIC ACID-PFHXS	1.24	J		0.578	2.00
375-95-1	PERFLUORONONANOIC ACID-PFNA	ND			0.578	2.00
375-85-9	PERFLUROHEPTANOIC ACID-PFHPA	1.63	J		0.578	2.00
335-76-2	PERFLURODECANOIC ACID - PFDA	ND			0.578	2.00
PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA, and PFDA; only include results at or above the MRL; do not include estimated results as described by a Result Qualifier in the next column)		4.65		20	0.578	2.00
UNREGULATED PFAS CONTAMINANTS						
375-73-5	PERFLUROBUTANESULFONIC ACID-PFBS	1.97	J		0.578	2.00
307-55-1	PERFLURODODECANOIC ACID - PFDOA	ND			0.578	2.00
307-24-4	PERFLUROHEXANOIC ACID - PFHXA	2.68			0.578	2.00
376-06-7	PERFLUROTETRADECANOIC ACID - PFTTA	ND			0.578	2.00
72629-94-8	PERFLUROTRIDECANOIC ACID - PFTRDA	ND			0.578	2.00
2058-94-8	PERFLUROUNDECANOIC ACID - PFUNA	ND			0.578	2.00
2991-50-6	N-ETHYL PERFLUROOCTANESULFONAMIDOACETIC ACID - NETFOSAA	ND			0.578	2.00
2355-31-9	N-METHYL PERFLUROOCTANESULFONAMIDOACETIC ACID - NMEFOSAA	ND			0.578	2.00
763051-92-9	11-CHLOROICOSAFLURO-3-OXAUNDECANE-1-SULFONIC ACID-11CL-PF3OUDS	ND			0.578	2.00
756426-58-1	9-CHLOROHEXADECAPLURO-3-OXANONE-1-SULFONIC ACID-9CL-PF3ONS	ND			0.578	2.00
919005-14-4	4,8-DIOXA-3H-PERFLURONONANOIC ACID - ADONA	ND			0.578	2.00
13252-13-6	HEXAFLUROPROPYLENE OXIDE DIMER ACID - HFPO-DA	ND			0.578	2.00

1. A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.  
 2. All qualifiers must be described under Lab Analysis Comments on page 2.  
 Rev 9/9/2020

