



Massachusetts Department of Environmental Protection - Drinking Water Program  
Per- and Polyfluoroalkyl Substances (PFAS) Report

PFAS

Page 1 of 2

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: 3164000  
PWS Name: LYNNFIELD CENTER WATER DISTRICT City/Town: LYNNFIELD  
PWS Class: COM NTNC  TNC -

DEP LOCATION (LOC) ID#	DEP Location Name	Sample Information	Date Collected	Collected By
10272	STATION #2 (MAIN ST GP WELL)	<input type="checkbox"/> (M)ultiple <input type="checkbox"/> (R)aw <input type="checkbox"/> (S)ingle <input type="checkbox"/> (F)inished	2/15/2022	B. Deshaies
Routine or Special Sample <input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	Original, Resubmitted or Confirmation Report X Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	If Resubmitted Report, list below: (1) Reason for Resubmission: <input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction (2) Collection Date of Original Sample:		

SAMPLE NOTES -- (Such as, if a Manifold/Multiple sample, list any sources that were on-line during sample collection).

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #: M-MA1118  
Analysis Lab Cert. #: M-MA072  
Primary Lab Name: Nashoba Analytical, LLC  
Analysis Lab Name: New England ChromaChem  
Subcontracted? (Y/N) Y

If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Primary Lab:	Lab Sample IDs#
EPA537.1	2/18/2022	2/18/2022	1		239266-1 202301

CAS #	Regulated PFAS Contaminants	Result ng/L	Result Qualifier	MCL ng/L	MCL MDL ng/L	MRL ng/L
1763-23-1	PERFLUOROOCETANESULFONIC ACID-PFOS	5.38			0.623	2.00
335-67-1	PERFLUOROOCETANOIC ACID-PFOA	7.32			0.623	2.00
355-46-4	PERFLUOROHXANESULFONIC ACID-PFHXS	1.47	J		0.623	2.00
375-95-1	PERFLUORONONANOIC ACID-PFNA	0.664	J		0.623	2.00
375-85-9	PERFLUROHEPTANOIC ACID-PFHPA	2.99			0.623	2.00
335-76-2	PERFLURODECANOIC ACID - PFDA	ND			0.623	2.00
	PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA, and PFDA; only include results at or above the MRL; do not include estimated results as described by a Result Qualifier in the next column)	15.7		20	0.623	2.00
UNREGULATED PFAS CONTAMINANTS						
375-73-5	PERFLUROBUTANESULFONIC ACID-PFBS	2.33			0.623	2.00
307-55-1	PERFLURODODECANOIC ACID - PFDOA	ND			0.623	2.00
307-24-4	PERFLUROHEXANOIC ACID - PFHXA	4.69			0.623	2.00
376-06-7	PERFLUROTETRADECANOIC ACID - PFTA	ND			0.623	2.00
72629-94-8	PERFLUROTRIDECANOIC ACID - PFTRDA	ND			0.623	2.00
2058-94-8	PERFLUROUNDECANOIC ACID - PFUNA	ND			0.623	2.00
2991-50-6	N-ETHYL PERFLUROOCETANESULFONAMIDOACETIC ACID - NETFOSAA	ND			0.623	2.00
2355-31-9	N-METHYL PERFLUROOCETANESULFONAMIDOACETIC ACID - NMEFOSAA	ND			0.623	2.00
763051-92-9	11-CHLOROHEXACOSAFLUORO-3-OXAUNDECANE-1-SULFONIC ACID-11CL-PF30US	ND			0.623	2.00
756426-58-1	9-CHLOROHEXADECALFUORO-3-OXANONE-1-SULFONIC ACID-9CL-PF30NS	ND			0.623	2.00
919005-14-4	4,8-DIOXA-3H-PERFLURONONANOIC ACID - ADONA	ND			0.623	2.00
13252-13-6	HEXAFLUROPROPYLENE OXIDE DIMER ACID - HFPO-DA	ND			0.623	2.00

A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.  
All qualifiers must be described under Lab Analysis Comments on page 2.  
Rev 9/9/2020

