



# NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432  
Phone: 978-391-4428 | website: www.nashobaanalytical.com

## DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 11/01/2022  
SAMPLE ID #: 2210-03515-001  
SAMPLED BY: Deshaies, Brian

LAB ID#: M-MA030

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

SAMPLE CATEGORY: Routine Sample  
SYSTEM NAME: Lynnfield Center Water District  
EPA ID#: 3164000  
SYSTEM TOWN: Lynnfield  
SAMPLE AGENT #:   
SAMPLE LOCATION: 10272 STATION #2 (MAIN ST GP WELL)

DATE & TIME COLLECTED: 10/18/2022 10:50AM  
DATE & TIME RECEIVED: 10/18/2022 01:10PM  
WATER SYS TYPE:  
RECEIPT TEMP: NA  
CLIENT JOB #:

### BAR CODE:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-chloroeicosafuoro-3-oxaundecane-1-sulfonic Acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
4,8-dioxa-3H-perfluorononanoic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Date Extracted	-					No Limit	EPA 537.1	MA00030	10/27/2022 01:00PM
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorobutanesulfonic Acid (PFBS)*	3.20	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorododecanoic Acid (PFDoA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluoroheptanoic Acid (PFHpA)*	4.73	ng/L			Sub Report		EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorohexanesulfonic Acid (PFHxS)*	1.82	ng/L		J	Sub Report		EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorohexanoic Acid (PFHxA)*	6.37	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorononanoic Acid (PFNA)*	0.728	ng/L		J	Sub Report		EPA 537.1	MA00030	10/28/2022 06:00PM

Peter C. Nevius  
Laboratory Director



# NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432  
 Phone: 978-391-4428 | website: www.nashobaanalytical.com

## DRINKING WATER COMPLIANCE REPORT

**DATE PRINTED:** 11/01/2022  
**SAMPLE ID #:** 2210-03515-001  
**SAMPLED BY:** Deshaies, Brian

**LAB ID#:** M-MA030

**SAMPLE CATEGORY:** Routine Sample  
**SYSTEM NAME:** Lynnfield Center Water District  
**EPA ID#:** 3164000  
**SYSTEM TOWN:** Lynnfield  
**SAMPLE AGENT #:**  
**SAMPLE LOCATION:** 10272 STATION #2 (MAIN ST GP WELL)

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

**DATE & TIME COLLECTED:** 10/18/2022 10:50AM  
**DATE & TIME RECEIVED:** 10/18/2022 01:10PM  
**WATER SYS TYPE:**  
**RECEIPT TEMP:** NA  
**CLIENT JOB #:**

**BAR CODE:**

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorooctanesulfonic Acid (PFOS)*	6.52	ng/L			Sub Report		EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorooctanoic Acid (PFOA)*	11.4	ng/L			Sub Report		EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorotetradecanoic Acid (PFTA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluorotridecanoic Acid (PFTrDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Perfluoroundecanoic Acid (PFUnA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:00PM
Total 6 (PFOS PFOA PFNA PFHxS PFHpA PFDA)	22.7	ng/L	✕		Sub Report	20 ng/L Proposed	N/A calculation	MA00030	10/28/2022 06:00PM

Peter C. Nevius  
 Laboratory Director