



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
 Phone: 978-391-4428 | website: www.nashobaanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 11/01/2022
 SAMPLE ID #: 2210-03518-001
 SAMPLED BY: Deshaies, Brian

LAB ID#: M-MA030

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

SAMPLE CATEGORY: Routine Sample
 SYSTEM NAME: Lynnfield Center Water District
 EPA ID#: 3164000
 SYSTEM TOWN: Lynnfield
 SAMPLE AGENT #:
 SAMPLE LOCATION: ST3 STA. #3 (GWTP) - FINISHED WATER

DATE & TIME COLLECTED: 10/18/2022 10:15AM
 DATE & TIME RECEIVED: 10/18/2022 01:10PM
 WATER SYS TYPE:
 RECEIPT TEMP: NA
 CLIENT JOB #:

BAR CODE:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-chloroeicosafuoro-3-oxaundecane-1-sulfonic Acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
4,8-dioxa-3H-perfluorononanoic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Date Extracted	-					No Limit	EPA 537.1	MA00030	10/27/2022 01:00PM
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorobutanesulfonic Acid (PFBS)*	2.15	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorododecanoic Acid (PFDoA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluoroheptanoic Acid (PFHpA)*	0.764	ng/L		J	Sub Report		EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorohexanesulfonic Acid (PFHxS)*	0.91	ng/L		J	Sub Report		EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorohexanoic Acid (PFHxA)*	2.26	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorononanoic Acid (PFNA)*	<2.00	ng/L			Sub Report		EPA 537.1	MA00030	10/28/2022 06:17PM

Peter C. Nevius
 Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
 Phone: 978-391-4428 | website: www.nashobaanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 11/01/2022
 SAMPLE ID #: 2210-03518-001
 SAMPLED BY: Deshaies, Brian

LAB ID#: M-MA030

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
 SYSTEM NAME: Lynnfield Center Water District
 EPA ID#: 3164000
 SYSTEM TOWN: Lynnfield
 SAMPLE AGENT #:
 SAMPLE LOCATION: ST3 STA. #3 (GWTP) - FINISHED WATER

DATE & TIME COLLECTED: 10/18/2022 10:15AM
 DATE & TIME RECEIVED: 10/18/2022 01:10PM
 WATER SYS TYPE:
 RECEIPT TEMP: NA
 CLIENT JOB #:

BAR CODE:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorooctanesulfonic Acid (PFOS)*	2.04	ng/L			Sub Report		EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorooctanoic Acid (PFOA)*	2.98	ng/L			Sub Report		EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorotetradecanoic Acid (PFTA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluorotridecanoic Acid (PFTDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Perfluoroundecanoic Acid (PFUnA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	10/28/2022 06:17PM
Total 6 (PFOS PFOA PFNA PFHxS PFHpA PFDA)	5.02	ng/L	✓		Sub Report	20 ng/L Proposed	N/A calculation	MA00030	10/28/2022 06:17PM

Peter C. Nevius
 Laboratory Director