



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 11/28/2022
SAMPLE ID #: 2211-02730-001
SAMPLED BY: Brian Deshaies/David Ball

LAB ID#: M-MA030

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Lynnfield Center Water District
EPA ID#: 3164000
SYSTEM TOWN: Lynnfield
SAMPLE AGENT #:
SAMPLE LOCATION: 10275 STA. #4 (GLEN DRIVE WELLS 5G-8G)

DATE & TIME COLLECTED: 11/14/2022 08:55AM
DATE & TIME RECEIVED: 11/14/2022 11:21AM
WATER SYS TYPE:
RECEIPT TEMP: 15.4° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
4,8-dioxa-3H-perfluorononanoic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Date Extracted	-					No Limit	EPA 537.1	MA00030	11/22/2022 06:09PM
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorobutanesulfonic Acid (PFBS)*	3.29	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorododecanoic Acid (PFDoA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluoroheptanoic Acid (PFHpA)*	2.54	ng/L			Sub Report		EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorohexanesulfonic Acid (PFHxS)*	1.61	ng/L		J	Sub Report		EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorohexanoic Acid (PFHxA)*	4.93	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorononanoic Acid (PFNA)*	<2.00	ng/L			Sub Report		EPA 537.1	MA00030	11/24/2022 04:05AM

Peter C. Nevius
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
 Phone: 978-391-4428 | website: www.nashobaanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 11/28/2022
 SAMPLE ID #: 2211-02730-001
 SAMPLED BY: Brian Deshaies/David Ball

LAB ID#: M-MA030

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
 SYSTEM NAME: Lynnfield Center Water District
 EPA ID#: 3164000
 SYSTEM TOWN: Lynnfield
 SAMPLE AGENT #:
 SAMPLE LOCATION: 10275 STA. #4 (GLEN DRIVE WELLS 5G-8G)

DATE & TIME COLLECTED: 11/14/2022 08:55AM
 DATE & TIME RECEIVED: 11/14/2022 11:21AM
 WATER SYS TYPE:
 RECEIPT TEMP: 15.4° CELSIUS
 CLIENT JOB #:

BAR CODE:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorooctanesulfonic Acid (PFOS)*	3.88	ng/L			Sub Report		EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorooctanoic Acid (PFOA)*	7.47	ng/L			Sub Report		EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorotetradecanoic Acid (PFTA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluorotridecanoic Acid (PFTTrDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Perfluoroundecanoic Acid (PFUnA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	11/24/2022 04:05AM
Total 6 (PFOS PFOA PFNA PFHxS PFHpA PFDA)	13.9	ng/L	✓		Sub Report	20 ng/L Proposed	N/A calculation	MA00030	11/24/2022 04:05AM

Peter C. Nevius
 Laboratory Director