



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 01/05/2023
SAMPLE ID #: 2212-02022-001
SAMPLED BY: Deshaies, Brian

LAB ID#: M-MA030

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Lynnfield Center Water District
EPA ID#: 3164000
SYSTEM TOWN: Lynnfield
SAMPLE AGENT #:
SAMPLE LOCATION: 10275 STA. #4 (GLEN DRIVE WELLS 5G-8G)

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

DATE & TIME COLLECTED: 12/12/2022 09:47AM
DATE & TIME RECEIVED: 12/12/2022 11:27AM
WATER SYS TYPE:
RECEIPT TEMP: ON ICE 15.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-chloroeicosafuoro-3-oxaundecane-1-sulfonic Acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
4,8-dioxa-3H-perfluorononanoic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Date Extracted	-					No Limit	EPA 537.1	MA00030	12/19/2022 06:53PM
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorobutanesulfonic Acid (PFBS)*	2.94	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorododecanoic Acid (PFDoA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluoroheptanoic Acid (PFHpA)*	2.06	ng/L			Sub Report		EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L			Sub Report		EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorohexanoic Acid (PFHxA)*	4.54	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorononanoic Acid (PFNA)*	<2.00	ng/L			Sub Report		EPA 537.1	MA00030	12/26/2022 08:33PM

Peter C. Nevius
 Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 01/05/2023
SAMPLE ID #: 2212-02022-001
SAMPLED BY: Deshaies, Brian

LAB ID#: M-MA030

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Lynnfield Center Water District
EPA ID#: 3164000
SYSTEM TOWN: Lynnfield
SAMPLE AGENT #:
SAMPLE LOCATION: 10275 STA. #4 (GLEN DRIVE WELLS 5G-8G)

DATE & TIME COLLECTED: 12/12/2022 09:47AM
DATE & TIME RECEIVED: 12/12/2022 11:27AM
WATER SYS TYPE:
RECEIPT TEMP: ON ICE 15.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorooctanesulfonic Acid (PFOS)*	3.47	ng/L			Sub Report		EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorooctanoic Acid (PFOA)*	6.28	ng/L			Sub Report		EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorotetradecanoic Acid (PFTA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluorotridecanoic Acid (PFTrDA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Perfluoroundecanoic Acid (PFUnA)*	<2.00	ng/L			Sub Report	No Limit	EPA 537.1	MA00030	12/26/2022 08:33PM
Total 6 (PFOS PFOA PFNA PFHxS PFHpA PFDA)	11.8	ng/L	✓		Sub Report	20 ng/L Proposed	N/A calculation	MA00030	12/26/2022 08:33PM

Peter C. Nevius
Laboratory Director